

Addendum #1 – January 8, 2023

IFB230119

McHenry County College

This Addendum constitutes changes to the General conditions Contract as sent out in the original IFB and other pertinent information shared with all vendors. All changes and information listed on this Addendum should be considered as the official modifications to the specifications and should be included in your proposal with these in mind. Section as listed UTILIZATION PLAN after section 4.3. of the BEP section. shall read as described.

---

UTILIZATION  
PLAN

**The Utilization Plan and Letter of Intent must be sealed and submitted with Vendor's Bid Documents.**

\_\_\_\_\_ (Vendor) submits the following Utilization Plan as part of our bid or offer in accordance with the requirements of the BEP Program Status and Participation section of the solicitation for McHenry County College's

**\_\_\_A260 RENOVATION IFB230119\_\_\_\_\_** (Project Name).

---

Other Questions and answers (in bold) as requested:

1. What size is the light kit for the door? **20"Hx36"L**
2. What is the wall thickness that the doors are going into? **4 7/8" Thick**
3. What is the required finish of the hardware? **Nickel finish hinges. Locksets are provided by customer (MCC)**
4. What size is the kickplate? **34"Lx20"H**
5. You reference sound insulated walls. Is there a specific insulation wanted or STC rating? **Standard sound insulation (per local code)**
6. The bid form attached to this project (Part 4 – Offer) references a different project name. **See BEP section correction above.**