Addendum #2 – March 4, 2021 IFB03112021 Landscape Maintenance Service McHenry County College

This Addendum is in response to the inquiries from potential bidders. This Addendum constitutes changes to the specifications as sent out in the original IFB and other pertinent information shared with all vendors. All changes and information listed on this Addendum should be considered as the official modifications to the specifications and should be included in your proposal with these in mind.

Please acknowledge your receipt of this addendum by attaching a signed copy of the addendum with your proposal response.

Received and acknowledged by:	

- 1. What is wattage of existing fixtures? 2x4-31.69 watts, 2x2-26.3 watts, 1x4-33.09 watts
- 2. Are they just 2x4 or do they have lamps inside? if so how many lamps? All LED Light-emitting diodes.
- 3. Burn Hours= how long are lights on? Approx. 15 Hrs a day
- 4. Are these all drop ceilings? Yes all drop ceilings
- 5. Ceiling Height- do any lights require a lift? (thinking stairwells or maybe an auditorium room). Stairwells and auditorium