

Architectural Consulting Group, Ltd.

Architects / Consultants

422 N. Hough St
Barrington, IL60010
Phone: 847.277.1900
Fax: 847.277.1300

BIDDING REQUIREMENTS

Addendum No 2

Date : April 23, 2021

From : Dave Myszka – Project Manager

Subject : Addendum No. 2 to the Bidding Documents for:

Project No.: ACG File No. 21-033

Roof Rehabilitation Program Building 'D' McHenry County College

This Addendum forms a part of the Contract Documents and modifies the bidding documents (3-25-21) and drawings (3-15-21) .

Bidders are instructed to acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so will subject the Bidder to disqualification.

Clarifications

- A. In lieu of all references to roof assembly FM 1-300, the new completed roofing assembly shall have a total system rating of UL Class A and meet a minimum **FM I-90** uplift rating.

Section 07 52 13 APP Modified Roofing / Cap Sheet Flashings:

Top Ply: Derbicolor XPS-FR-CR (2N2X - FR DC-CR) – White granular surfaced (Energy Star Approved) Fire retardant triple reinforced APP Modified Bitumen sheet with fiberglass and polyester composite matting and coated granular surfacing with a minimum overall sheet thickness of (180 mil) and having a minimum Tensile Strength at 0 degrees Fahrenheit of 230 lbs. force/in. in all directions and a tear resistance at 71 degrees Fahrenheit of 200 lbs. force/in in all directions per ASTM and as manufactured by Derbigum Americas, Inc or approved equal. Testing shall conform with ASTM D 6223-02.

Bid due date remains unchanged—April 28, 2021

Very truly yours,

Architectural Consulting Group, Ltd

Dave Myszka

Project Manager