

**SECTION 00 90 04  
BIDDING AND CONTRACT REQUIREMENTS  
ADDENDUM NUMBER 4**

**Demonica Kemper Architects  
125 N. Halsted Street, Suite 301  
Chicago, IL 60661  
312.496.0000**

To: Prospective Bidders

Issued: November 8, 2024

**Re: ADDENDUM NUMBER (4) TO THE BIDDING DOCUMENTS FOR**

**McHenry County College  
2024 Renovations – Bid Package 2**  
Architect's Project Number: 24-013

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents dated October 17, 2024. Acknowledge receipt of this addendum in the space provided on Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

**ADDENDA TO THE PROJECT MANUAL**

None

**ADDENDA TO THE DRAWINGS**

None

**CLARIFICATIONS**

1. FM200 Scope Clarification.
  - A. There will be no modifications required to the existing FM200 Fire Protection system in the IT Server Room (1<sup>st</sup> Floor, Building A). The Contractor will be responsible for protecting the existing piping and FM200 Sprinkler Head throughout construction. The Contractor will be responsible for removing, salvaging, and reinstalling the Heat Detectors associated with the FM200 system with the demolition of the existing ceiling and installation of the new ceiling system.

**This addendum consists of 1 pages, excluding attachments.**

**END 00 90 04.**

**Attachments:**

None