

RFP Questions

Bid Title	A124 Remodel
Bid #	RFP#04162026
Question	ACT spec?
Answer	Armstrong 704
Question	ACT ceiling height
Answer	9'0"
Question	2 nd floor deck height from first floor
Answer	13'0"
Question	Do all walls go to 2 nd floor deck?
Answer	Yes
Question	MCC to provide all doors and hardware, will these materials be brought to unit 124 by MCC employees?
Answer	MCC is supplying all door hardware, not all doors and hardware
Question	List of general contractors or plan holders for this project
Answer	MCC will be the GC and plan holder.
Question	The office entrance frames look to be Raco-style interior frames with a snap-on trim around the drywall, while the Collab and computer lab example photo looks to have cased drywall openings and full height recessed storefront. Can you confirm this is the case?
Answer	Yes, confirmed.