

Date: May 11, 2016
From: 20/10 Engineering

To:
SUBJECT: ADDENDUM NO. 1 TO THE BID DOCUMENTS FOR:

Building 'D' 2016 Boiler Replacement
McHenry County College
8900 US Hwy 14 – Building 'D'
Crystal Lake, IL 60012
Proj. No. 1550-a-13

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents, dated April 13, 2016. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

SPECIFICATION

1. Section 00 11 16 – Invitation to Bid: Revise time of bid receipt on Page 1 from 10:00 am to 8:00 am.

DRAWINGS

1. None.

CLARIFICATION

1. Boilers to be provided with BACnet IP control interface.

This addendum consists of the following: (1) 8 ½" x 11" pages and (0) revised specification sections.

END OF ADDENDUM 1