

**ADDENDUM NUMBER ONE**

DATE: 11 July 2013

PROJECT: Ceramics Lab Ventilation  
Building A  
McHenry County College  
8900 US Highway 14  
Crystal Lake, Illinois 60012

OWNER: McHenry County College  
8900 US Highway 14  
Crystal Lake, Illinois 60012

ARCHITECT'S PROJECT NO. 1227.04

ARCHITECT: RuckPate Architecture  
22102 North Pepper, Suite 201  
Barrington, Illinois 60010

**TO ALL BIDDERS OF RECORD:**

This Addendum forms a part of a modification to the bid requirements and proposed contract documents for the subject project, dated 14 January 2013. Receipt of this Addendum shall be acknowledged in the Form of Bid. Failure to do so may subject the bidder to disqualification. This Addendum consists of eight (1) pages, three (3) items, Bid Documents are hereby amended as follows:

**PROJECT MANUAL**

<b>ITEM</b>	<b>DESCRIPTION</b>
-------------	--------------------

**DRAWINGS**

Reference: Sheet M121- Partial Second Floor Plan - Ventilation

1. Delete note "Alternate #1....." in its entirety and insert "Alternate #:1 Re-use existing ductwork within clouded area as shown and connect to new exhaust fan. Base Bid: Replace ductwork within clouded area. Provide new connection to new exhaust fan."
2. Partial Second Floor - Mechanical Demolition. Delete note "Cut and patch wall..." in its entirety.

**CLARIFICATION**

3. The bid includes all of the work shown on the documents. We are not separate trade bids.

End of Addendum

