

Addendum #1
RFP04152014B
Shah Center – Natural Gas Hot Water Heater Replacement Services
McHenry County College

This Addendum is in response to the inquiries from potential bidders. This Addendum constitutes changes to the specifications as sent out in the original RFP and other pertinent information shared with all vendors. All changes and information listed on this Addendum should be considered as the official modifications to the specifications and should be included in your proposal with these in mind.

Please acknowledge your receipt of this addendum by attaching a signed copy of the addendum with your proposal response.

Received and acknowledged by: _____

-
1. A properly sized and approved expansion tank shall be located on the water heater's cold water supply with no shut-off between the heater and the expansion tank.
 2. A properly sized and approved ball valve will be installed on the water heater's cold water supply.